

Drinking Water Systems Regulation O.Reg. 170/03

HERMON PUBLIC SCHOOL ANNUAL REPORT

Drinking water system number:	260013975
Drinking water system name:	Hermon Public School
Drinking water system owner:	Hastings and Prince Edward District School Board
Drinking water system category:	Small Non-Municipal Non-Residential
Period Being Reported:	April 1, 2022 - March 31, 2023

Number of Designated Facilities Served:	1
Copies provided of annual report to all designated facilities served:	YES
Number of interested authorities you report to:	3
Copies provided of annual report to all interested authorities for each designated facility served:	YES
List all drinking water systems (if any) which receive all of their drinking water from your system:	Hermon Public School
Copies provided of annual report to all drinking water system owners to whom you provide all of its drinking water:	YES
Indicate method of notifying system users of annual report availability free of charge:	Website and Public Request

Description of Drinking Water System:

The Hermon Public School drinking water system consists of one well equipped with a submersible pump that supplies raw water to a mechanical room in the school. The water is passed through a multimedia filter; then passes through two cartridge filters. Sodium hypochlorite is added through a feed pump. Chlorinated water then flows through a UV disinfection unit equipped with a solenoid valve that shuts down water in instances of poor water quality or loss of power; the solenoid is tested weekly. Chlorine residual is measured each day the school is open.

A service contract is in place with OCWA (Ontario Clean Water Agency) to maintain the treatment system.

To satisfy treatment requirements as described in Ontario Regulation 170/03, Ultraviolet disinfection equipment is used as primary disinfection. In addition to meeting the minimum treatment requirement we add chlorination as a means of secondary disinfection, though it is not required in this system. The free chlorine residual is sampled and recorded on a daily basis and the UV solenoid is tested for proper functioning on a weekly basis.

A professional engineer hired by the Board certified that the water supply and works do meet the minimum standards set out in the Ontario Regulation 170/03. They also certified that the minimum treatment laid out in Schedule 2 of the regulations is being complied with and that all equipment required in order to carry out the period checks in compliance with Schedule 6 and Schedule 9 of the regulations is provided.

Water treatment chemicals used over this reporting period:

12% Sodium hypochlorite solution

Drinking Water Systems Regulation O.Reg. 170/03

Significant Expenses incurred included (0=N/A, X=APPLICABLE):

0	Install Required Equipment
0	Repair Required Equipment
X	Replace Required Equipment

Description and breakdown of monetary expenses incurred: April 1, 2022 - March 31, 2023

Water system upgrades and replacements:

No major upgrades or replacements of equipment were completed during this year.

\$0.00

Routine system maintenance (Including service contracts):

Regular maintenance includes monthly checks of the water treatment system by a service contractor and the minor repair/replacement of necessary parts/equipment(including cistern maintenance). The costs, tax excluded, for regular maintenance on water treatment

\$5,917.77

Water sampling and analysis:

The cost for microbiological and chemical water sampling by Greer Galloway and analytical fees was:

\$4,911.39

Staff Training:

Costs for required training of staff under Ontario Regulation 170/03 was:

\$304.62

Details on notices submitted in accordance with subsection 18(1) of the SDWA or section 16-4 of Schedule 16 of O.Reg. 170/03 and reported to SAC:

April 1, 2022 - March 31, 2023

Incident Date	Parameter	Result	Corrective Action	Corrective action date
None.				

Microbiological testing done under the Schedule 10, 11 or 12 of O.Reg 170/03:

April 1, 2022 - March 31, 2023

	Number of samples	Range of E.Coli or Fecal Results (min-max)	Range of TC Results (min-max)
Raw	13	0-0	0-0
Treated- Staff Kitchen	22	0-0	0-0
Distribution	22	0-0	0-0

Operational testing done under Schedule 7, 8 or 9 of O.Reg. 170/03:

April 1, 2022 - March 31, 2023

	Number of Grab Samples	Range of Results (min-max)
Turbidity	22	0.08-0.20
Chlorine	224	0.20-1.04

Drinking Water Systems Regulation O.Reg. 170/03

Inorganic testing done during this reporting period or most recent sample results:				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	31-May-21	<0.0001	mg/L	No
Arsenic	31-May-21	0.0002	mg/L	No
Barium	31-May-21	0.016	mg/L	No
Boron	31-May-21	0.006	mg/L	No
Cadmium	31-May-21	<0.000015	mg/L	No
Chromium	31-May-21	<0.002	mg/L	No
Fluoride	31-May-21	<0.1	mg/L	No
Lead- STANDING	22-Jun-22	0.00116	mg/L	No
Lead - FLUSHED		0.00062	mg/L	No
Mercury	31-May-21	<0.00002	mg/L	No
Nitrite	14-Mar-23	0.05	mg/L	No
Nitrate		1.1	mg/L	No
Selenium	31-May-21	<0.001	mg/L	No
Sodium	31-May-21	26.8	mg/L	Yes
Uranium	31-May-21	<0.00005	mg/L	No

Organic testing done during this reporting period or most recent sample results:				
Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	31-May-21	< 0.0003	mg/L	No
Atrazine + N-dealkylated metabolites	31-May-21	< 0.0005	mg/L	No
Azinphos-methyl	31-May-21	< 0.001	mg/L	No
Benzene	31-May-21	< 0.0005	mg/L	No
Benzo(a)pyrene	31-May-21	< 0.000006	mg/L	No
Bromoxynil	31-May-21	< 0.0005	mg/L	No
Carbaryl	31-May-21	< 0.003	mg/L	No
Carbofuran	31-May-21	< 0.001	mg/L	No
Carbon Tetrachloride	31-May-21	< 0.0002	mg/L	No
Chlorpyrifos	31-May-21	< 0.0005	mg/L	No
Diazinon	31-May-21	< 0.001	mg/L	No
Dicamba	31-May-21	< 0.01	mg/L	No
1,2-Dichlorobenzene	31-May-21	< 0.0005	mg/L	No
1,4-Dichlorobenzene	31-May-21	< 0.0005	mg/L	No
1,2-Dichloroethane	31-May-21	< 0.0005	mg/L	No
1,1-Dichloroethylene (vinylidene chloride)	31-May-21	< 0.0005	mg/L	No
Dichlormethane	31-May-21	< 0.005	mg/L	No
2,4-Dichlorophenol	31-May-21	< 0.0002	mg/L	No
2,4-Dichlorophenoxyacetic acid (2,4-D)	31-May-21	< 0.01	mg/L	No
Diclofop-methyl	31-May-21	< 0.0009	mg/L	No
Dimethoate	31-May-21	< 0.001	mg/L	No
Diquat	31-May-21	< 0.005	mg/L	No
Diuron	31-May-21	< 0.005	mg/L	No
Glyphosate	31-May-21	< 0.025	mg/L	No

Drinking Water Systems Regulation O.Reg. 170/03

Malathion	31-May-21	< 0.005	mg/L	No
2-Methyl-4-chlorophenoxyacetic acid (MCPA)	31-May-21	< 0.01	mg/L	No
Metolachlor	31-May-21	< 0.003	mg/L	No
Metribuzin	31-May-21	< 0.003	mg/L	No
Monochlorobenzene	31-May-21	< 0.0005	mg/L	No
Paraquat	31-May-21	< 0.001	mg/L	No
Pentachlorophenol	31-May-21	< 0.0002	mg/L	No
Phorate	31-May-21	< 0.0003	mg/L	No
Picloram	31-May-21	< 0.015	mg/L	No
PolyChlorinated Biphenyls (PCB)	31-May-21	< 0.00005	mg/L	No
Prometryne	31-May-21	< 0.0001	mg/L	No
Simazine	31-May-21	< 0.0005	mg/L	No
Terbufos	31-May-21	< 0.0005	mg/L	No
Tetrachloroethylene	31-May-21	< 0.0005	mg/L	No
2,3,4,6-Tetrachlorophenol	31-May-21	< 0.0002	mg/L	No
Triallate	31-May-21	< 0.01	mg/L	No
Trichloroethylene	31-May-21	< 0.0005	mg/L	No
2,4,6-Trichlorophenol	31-May-21	< 0.0002	mg/L	No
Trifluarlin	31-May-21	0.0005	mg/L	No
Trihalomethanes (THM)	5-Oct-21	< 0.029	mg/L	No
Vinyl Chloride	31-May-21	< 0.0002	mg/L	No